

Sertifikat o kontrolisanju
Inspection certificate

SERTIFIKAT O KONTROLISANJU
INSPECTION CERTIFICATE

Broj / Number: **Z 2528**

Strana / Page: **1/2**

Na zahtev naručioca /
By the request of purchaser:

WELD PIPE d.o.o. SMEDEREVO

16. oktobra 64, Lokal br.3, 11300 Smederevo, Srbija / Serbia

preduzeto je /
set to:

Kontrolisanje dokumentacije i montaže

Inspection of installation and documentation

u vezi sa Izveštajem o kontrolisanju /
in relation to Inspection report:

Broj / Number: **Z 2528**

sa dokumentima u prilogu /
with enclosed documents:

- Sertifikat sistema menadžmenta /
Quality management certificate;
- Licence odgovornih izvođača radova /
Responsible contractor licenses;
- Liste resursa i podugovarači /
Resources and subcontractors lists;
- Specifikacije tehnologije zavarivanja i kvalifikacije tehnologije zavarivanja /
Welding procedure specifications and welding procedure qualifications;
- Uverenja o stručnoj osposobljenosti zavarivača /
Welder's qualification test certificates;
- Dokazi o resursima i mogućnostima za ispitivanja /
Evidence of resources and capabilities for testing;
- Uverenja o obučenosti osoblja /
Staff qualification certificates

INSTITUT "MIHAJLO PUPIN" - CENTAR ZA GASNU TEHNIKU izjavljuje da:
INSTITUTE "MIHAJLO PUPIN" - GAS TECHNIQUE CENTRE declares that:

predmet kontrolisanja /
the inspection object:

Cevi za daljinsko grejanje – Projektovanje i ugradnja toplotno izolovanih, kruto spojenih pojedinačnih i duplih cevovoda za neposredno ukopane toplovodne mreže /
District heating pipes - Design and installation of thermal insulated bonded single and twin pipe systems for directly buried hot water networks

proizveden od /
manufactured by:

WELD PIPE d.o.o. SMEDEREVO

16. oktobra 64, Lokal br.3, 11300 Smederevo, Srbija / Serbia

oznaka - tip - serija /
mark - type - series:

Predizolovani sistem /

Pre-insulated bonded pipe systems

kako je specificirano u Prilogu A, zadovoljava zahteve navedene u /
as specified in the Annex A, meets the requirements described in:

referentnom dokumentu /
reference document:

SRPS EN 13941-1:2022

SRPS EN 13941-2:2022

Sertifikat o kontrolisanju se izdaje na osnovu standarda SRPS ISO/IEC 17020:2012 .
The inspection certificate is issued on the basis of the standard SRPS ISO/IEC 17020:2012.

Nadzor usaglašenosti predmeta kontrolisanja se obezbeđuje sa
periodičnim kontrolisanjem do dana /

Surveillance of the inspection object compliance is assured by periodical inspection until the date:

27.12.2026

mesto, datum / place, date:

Beograd, 27.12.2025.

izdat od / issued by :

RUKOVODILAC CENTRA ZA GASNU TEHNIKU


GAS TECHNIQUE CENTRE MANAGER

Kristina Petković, M.Sc.M.E.

(Potpis / Signature)

INSTITUT
"MIHAJLO PUPIN"
CENTAR ZA
GASNU TEHNIKU
LABORATORIJA
Volgina 15
BEOGRAD
S R B I J A
tel: +381 11 6772 151
fax: +381 11 6781 029
impcgt@pupin.rs





SERTIFIKAT O KONTROLISANJU INSPECTION CERTIFICATE

Broj / Number: **Z 2528**
Strana / Page: **2/2**

Prilog A /

Annex A

oznaka - tip - serija /
mark - type - series:

Predizolovani sistem /
Pre-insulated bonded pipe systems

detaljno oznaka - tip - serija / mark - type - series specification:		tehničke karakteristike / technical characteristics:		kratak opis / short description:	
Predizolovani sistem / Pre-insulated bonded pipe systems		– za kontinualni rad sa toplom vodom temperature do 120°C i povremeno sa temperaturama do 140°C / for the continual operation with hot water temperature up to 120°C and casually with temperatures up to 140°C		Proizvođač ima na raspolaganju resurse i vrši montaže podzemnih sistema predizolovanih toplovodnih cevi i prenosne mreže sa cevnom konstrukcijom u skladu sa EN 253 / Manufacturer has available resources and perform the installations of underground pre-insulated bonded pipe systems and distribution networks with the pipe construction in accordance with EN 253	
		– za maksimalni unutrašnji pritisak do 25 bar / for the maximum internal pressure up to 25 bar			
		– projektna klasa A, B i C / project class A, B and C		i. cevi malog, srednjeg ili velikog prečnika i/ili visokog pritiska / pipes of small, medium or large diameter and/or high pressure ii. cevi sa velikim rizikom povrede radnika ili okoline / pipes with a high risk violation of workers or the environment iii. posebne složene konstrukcije / specific complex constructions	
Postupak zavarivanja / Welding process		Debljina osnovog mat. / Thickness PM		Prečnik cevi / Pipe diameter	
111		2,03÷5,8 mm* 3,0÷20,0 mm* 3,0÷24,0 mm*		≥ 30,15 mm ≥ 57,15 mm ≥ 500,0 mm	
141		3,0÷16,0 mm* 3,0÷20,0 mm*		≥ 54,0 mm ≥ 57,15 mm	
141 / 111		3,0÷20,0 mm*		≥ 57,15 mm	
135		3,0÷12,0 mm* 3,0÷40,0 mm*		≥ 150,0 mm ≥ 500,0 mm	
		* Sučioni zavar / Butt Weld (BW)			

Sertifikat o kontrolisanju
Inspection certificate